

05/07/25 BCC AGENDA SHEET

APP. NUMBER/OWNER/DESCRIPTION OF REQUEST

TM-25-500032-STARDUST TOWERS, LLC:

TENTATIVE MAP consisting of 83 single family attached residential lots and common lots on 6.32 acres in an RM18 (Residential Multi-Family 18) Zone.

Generally located on the north side of Pebble Road and the east side of Giles Street within Enterprise. MN/rr/kh (For possible action)

RELATED INFORMATION:

APN:

177-16-402-004; 177-16-405-001; 177-16-405-005; 177-16-405-009 through 177-16-405-010

LAND USE PLAN:

ENTERPRISE - COMPACT NEIGHBORHOOD (UP TO 18 DU/AC)

BACKGROUND:

Project Description

General Summary

- Site Address: N/A
- Site Acreage: 6.32
- Project Type: Single family attached residential
- Number of Lots: 83
- Density (du/ac): 13.13
- Minimum/Maximum Lot Size (square feet): 1,210/2,294

Project Description

The plan depicts a single-family residential attached development totaling 83 lots on 6.32 acres located on the east side of Giles Street and north side of Pebble Road. The density of the overall development is shown at 13.13 dwelling units per acre. The lots range in size from a minimum area of 1,210 square feet to a maximum of 2,294 square feet. Access to the development is from Giles Street to the west and Pebble Road to the south. The development's internal access is comprised of two, 39 foot wide private streets and four, 30 foot wide stub streets. Fifty-one guest parking spaces are indicated along the west side of Street A.

Prior Land Use Requests: APNs 177-16-402-004 & 177-16-405-001 only

Application Number	Request	Action	Date
ET-08-400353 (UC-0484-06)	Extension of time for a resort condominium - expired	Approved by BCC	January 2009
UC-0484-06	Use permit and design review for a 164-unit resort condominium - expired	Approved by BCC	December 2006

Prior Land Use Requests: APN 177-16-405-001 only

Application Number	Request	Action	Date
VS-0835-94	Vacate easements and public right-of-way being a portion of Torino Avenue	Approved by BCC	September 1994

Surrounding Land Use

	Planned Land Use Category	Zoning District (Overlay)	Existing Land Use
North	Neighborhood Commercial	CR	Single-family residential development
South	Neighborhood Commercial	CR	Multi-family residential development
East	Neighborhood Commercial & Ranch Estate Neighborhood (up to 2 du/ac)	CP & RS20 (NPO-RNP)	Commercial & single-family residential development
West	Entertainment Mixed-Use & Public Use	CR	Undeveloped & electric substation

Related Applications

Application Number	Request
PA-25-700010	A plan amendment to redesignate the existing land use category from Neighborhood Commercial (NC) to Compact Neighborhood (CN) is a companion item on this agenda.
ZC-25-0141	A zone change to reclassify the site from CR and RS20 to RM18 is a companion item on this agenda.
PUD-25-0143	A planned unit development for an 83 lot single-family attached residential development is a companion item on this agenda.
WS-25-0142	A waiver of development standards for an 83 lot single-family attached residential development is a companion item on this agenda.
VS-25-0140	A vacation and abandonment for easements and right-of-way is a companion item on this agenda.

STANDARDS FOR APPROVAL:

The applicant shall demonstrate that the proposed request is consistent with the Master Plan and is in compliance with Title 30.

Analysis**Comprehensive Planning**

This request meets the tentative map requirements and standards for approval as outlined in Title 30.

Department of Aviation

The property lies just outside the AE-60 (60-65 DNL) noise contour for the Harry Reid International Airport and is subject to continuing aircraft noise and over-flights. Future demand for air travel and airport operations is expected to increase significantly. Clark County intends to continue to upgrade the Harry Reid International Airport facilities to meet future air traffic demand.

Staff Recommendation

Approval. This item has been forwarded to the Board of County Commissioners for final action.

If this request is approved, the Board and/or Commission finds that the application is consistent with the standards and purpose enumerated in the Master Plan, Title 30, and/or the Nevada Revised Statutes.

PLANNING COMMISSION ACTION: April 1, 2025 – APPROVED – Vote: Aye: Frasier, Gibson, Mujica, Roitman, Stone Nay: Kilarski, Kirk

Comprehensive Planning

- Applicant is advised within 4 years from the approval date a final map for all, or a portion, of the property included in this application must be recorded or it will expire; an application for an extension of time may only be submitted if a portion of the property included under this application has been recorded; a substantial change in circumstances or regulations may warrant denial or added conditions to an extension of time; the extension of time may be denied if there has been no substantial work towards completion; and the applicant is solely responsible for ensuring compliance with all conditions and deadlines.

Public Works - Development Review

- Drainage study and compliance;
- Traffic study and compliance;
- Full off-site improvements;
- Clark County Fire Prevention approval to allow 10 units on a stub street;
- The installation of detached sidewalks will require the vacation of excess right-of-way and granting necessary easements for utilities, pedestrian access, streetlights, and traffic control devices.

Department of Aviation

- Applicant is advised that issuing a stand-alone noise disclosure statement to the purchaser or renter of each residential unit in the proposed development and to forward the completed and recorded noise disclosure statements to the Department of Aviation's Noise Office at landuse@lasairport.com is strongly encouraged; that the Federal Aviation Administration will no longer approve remedial noise mitigation measures for incompatible development impacted by aircraft operations which was constructed after October 1, 1998; and that funds will not be available in the future should the residents wish to have their buildings purchased or soundproofed.

Fire Prevention Bureau

- Provide a Fire Apparatus Access Road in accordance with Section 503 of the International Fire Code and Clark County Code Title 13, 13.04.090 Fire Service Features;
- All proposed single-family residential submittals will comply with code requirements for residential streets;

- 503.2.1.1 Parallel Parking Permitted on Both Sides. Where parallel parking is permitted on both sides of the fire apparatus access road, the minimum clear width of the fire apparatus road shall be 36 feet (10,972 mm), measuring 37 feet (11,277 mm) from back-of-curb to back-of-curb for L curbs, 38 feet (11,852 mm) from back-of-curb to back-of-curb for R curbs, and 39 feet (11,887 mm) from back-of-curb to back-of-curbs for roll curbs;
- The prohibition of parallel parking on both sides for the purpose of narrowing the roadway width is not permitted for fire apparatus roads serving one and two family dwellings;
- 503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 24 feet (7,315mm), exclusive of shoulders, except for approved access gates in accordance with 503.6, and an unobstructed vertical clearance of not less than 13 feet 6 inches (4,115mm).
- Applicant is advised that fire/emergency access must comply with the Fire Code as amended.

Clark County Water Reclamation District (CCWRD)

- Applicant is advised that a Point of Connection (POC) request has been completed for this project; email sewerlocation@cleanwaterteam.com and reference POC Tracking #0384-2024 to obtain your POC exhibit; flow contributions exceeding District estimates may require another POC analysis.

TAB/CAC: Enterprise - denial.

APPROVALS:

PROTESTS:

APPLICANT: EDDIE DUENAS

CONTACT: DARRYL LATTIMORE, ACTUS, 3283 E. WARM SPRINGS ROAD, SUITE 300, LAS VEGAS, NV 89120